

TABLE 1.11(A)
ROUTINE SERVICE FREQUENCIES FOR EACH SECTION

AS 1851 Section		Monthly	Three-monthly	Six-monthly	Yearly	Five-yearly	Ten-yearly	Twenty-five-yearly	Thirty-yearly
2	Automatic fire sprinkler systems	✓		✓	✓	✓	✓	✓	✓
3	Fire pumpsets	✓		✓	✓	✓	✓		
4	Fire hydrant systems	✓*			✓	✓			
	Hydrant valves			✓	✓				
5	Water storage tanks for fire protection systems	✓		✓	✓		✓		
6	Fire detection and alarm systems	✓		✓	✓	✓			
7	Special hazard systems	✓		✓	✓		✓		
8	Delivery lay flat fire hose				✓				
9	Fire hose reels			✓	✓				
10	Portable and wheeled fire extinguishers			✓	✓	✓			
11	Fire blankets			✓	✓				
12	Passive fire and smoke systems		✓**	✓	✓				
13	Fire and smoke control features of mechanical services	✓	✓	✓	✓	✓			
14	Emergency planning in facilities	✓		✓	✓				

*Where pumpsets are fitted.

**Where horizontal sliding doors are fitted.

17

AS 1851—2005

TABLE 1.11(A)
MAINTENANCE SECTIONS AND CORRESPONDING FREQUENCIES

AS 1851 Section		Frequencies								
		Weekly	Monthly	Three-monthly	Six-monthly	Yearly	Three-yearly	Five-yearly	Twelve-yearly	Twenty four-yearly
2	Sprinklers	✓ (1)			✓	✓	✓		✓ (2)	✓ (3)
3	Pumpsets	✓ (1)			✓	✓		✓		
4	Fire hydrant systems				✓	✓		✓		
5	Delivery lay flat fire hose					✓				
6	Detection		✓		✓	✓		✓		
7	Smoke and heat alarms		✓		✓	✓				
8	Fire alarm monitoring					✓				
9	Sound systems		✓		✓	✓		✓		
10	Intercom systems		✓		✓	✓				
11	Gaseous		✓		✓	✓		✓		
12	Aerosols		✓		✓	✓		✓		
13	Water mist		✓		✓	✓		✓		
14	Hose reels				✓	✓				
15	Portable and wheeled fire extinguishers				✓	✓		✓		
16	Fire blankets				✓					
17	Passive fire and smoke systems			✓	✓	✓				
18	Smoke Control & HVAC		✓	✓	✓	✓		✓		✓ (4)
19	Evacuation		✓		✓	✓				

NOTES:

- 1 Deletion of weekly tests are conditional (see Clause 2.2.1 and 3.2.1).
- 2 Dry pendent sprinklers 12 years after installation. Fast response sprinklers at 12 years, then 12 years, then every 6 years.
- 3 All other sprinklers at 24 years, then every 6 years.
- 4 Thermal links only.