



## SYSTEM CONDITION REPORT

Report Number: \_\_\_\_\_  
Period covered: 01/01/2018 to 31/12/2018  
Responsible Entity: \_\_\_\_\_  
Property Name: \_\_\_\_\_  
Property Address: \_\_\_\_\_

Systems Maintained	Maintenance Standards	Installation Standards (where known)
Exit & Emergency Lighting Single Point System	AS 2293.2 - 1995	AS2293.1
Fire Blankets	AS1851-2012 Section 11	AS-2444
Fire Detection Systems	AS1851-2012 Section 6	AS-1670
Fire Doorsets - Hinged & Pivoted	AS1851-2012 Section 12	AS-1905.1
Fire Extinguishers	AS1851-2012 Section 10	AS-2444
Fire Hose Reels	AS1851-2012 Section 9	AS-2441
Fire Hydrant Systems	AS1851-2012 Section 4	AS-2419
Smoke and Heat Alarms	AS1851-2012 Section 6	AS-1670
Smoke Doors	AS1851-2012 Section 12	AS-1905.1
Walls-Fire & Smoke Barriers	AS1851-2012 Section 12	AS-4072.1

**Statement:** I confirm that the system referred to above has been regularly inspected, tested, maintained and surveyed, to the applicable sections of AS 1851. With the exception of items detailed below in 'system defects', the system has been found to be functioning correctly and capable of performing to the design Standards nominated. Quotations have been issued for the items detailed below in 'system defects'.

### System Defects

Product Type

Contractor's representative:

Name: Trevor Voevodin	Date: 31/01/2019
Signature:	
<b>Contractor</b>	
Name: Fire Service Professionals Pty Ltd	
Address: 581 Old Cleveland Road Camp Hill QLD 4152	